

## SEMI-ANNUAL PREVENTATIVE MAINTENANCE ACTIVITIES

|   | Jan - Jun | Jul - Dec |
|---|-----------|-----------|
| Inspect and service kitchen hood extinguishment system, NFPA 96, 2011 edition 11.2.4  |           |           |
| Test supervisory valves, waterflow alarms, low air alarm (dry system) and main drain test on automatic sprinkler system, NFPA 25, 2011 Table 13.1.1.2 |           |           |
| Inspect all combustion air intakes & clean as required  |           |           |
|   |           |           |
|   |           |           |
|   |           |           |
|   |           |           |
|   |           |           |
|   |           |           |
|   |           |           |
|   |           |           |
|   |           |           |
|   |           |           |

02/07/18

Ensure power is disconnected from equipment prior to inspection and service.

This list is for example only and shall not be construed as encompassing all required preventative maintenance activities.